

CERTIFICATE

Certificate holder	Plasticos Rival Cia. Ltda. Ricaurte 252 010162 Cuenca ECUADOR
Production facility	Cuenca
Product	Pressure pipes made from Polyethylene (PE) for alternative installation techniques - PE 100-RC
Classification	EG 926.3, Outer diameter 250 mm up to 630 mm
Type, Model	PLASTICOS RIVAL
Remarks to the type	PAS 1075 Type 1 - TW Basis NTE INEN 1744
Testing basis	PAS 1075:2009-04 Certification Scheme Plastic Piping Systems (Pressure Pipes and Fittings) (2017-05)

Mark of conformity**Registration No.** P1R0584**Valid until** 2025-07-31**Right of use**

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.
See annex for further information.

2020-07-09

Robert Zorn M.Sc.
Managing Director

ANNEX

Page 1 of 1

Certificate

P1R0584 dated 2020-07-09

Technical DataPAS 1075 Type 1 - TW
Basis NTE INEN 1744

Outer diameter 250 mm up to 630 mm

Minimum wall thickness: 10,0 mm

Material: PE 100-RC

Type: see production facility related material list

Colour: black with blue stripes

Operating over pressure burstlining: not included

**Testing laboratory/
Inspection body**Hessel Ingenieurtechnik GmbH
Am Münsterwald 3
52159 Roetgen
GERMANY**Test report(s)**R20 03 3910-A4-A5_PLT+ dated 2020-07-09
R20 03 3910-A6-A7_PLT_interim report dated 2020-07-09
R20 03 3910-A_ACT dated 2020-07-09